

SECOND FLOOR NEW WORK PLAN H202 | SCALE: 1/8" = 1'-0"

## **KEY NOTES:**

- 1 PROVIDE NEW 4" RIGID EXHAUST VENT FROM BACK OF NEW DRYER THROUGH THE BOTTOM OF EXTERIOR WALL. TERMINATE WITH BACK DRAFT DAMPER AND DRYER VENT CAP. USE RIGID RADIUS ELBOW FOR CONNECTION TO DRYER. NEW PENETRATION SHOULD BE ABOVE EXISTING FIN TUBE.
- REINSTALL EXISTING SUPPLY DIFFUSER IN NEW LOCATION SHOWN.
  EXTEND DUCTWORK AND PROVIDE NEW VOLUME DAMPER. BALANCE TO AIRFLOW SHOWN.
- PROVIDE NEW BATHROOM EXHAUST GRILLES AND CONNECT TO EXISTING EXHAUST DUCTWORK AT POINT INDICATED. PROVIDE MANUAL VOLUME DAMPER FOR EACH BRANCH DUCT.
- 4 BALANCE EXISTING GRILLE TO AIRFLOW SHOWN



CPL | Architecture Engineering Planning 26 IBM Road Poughkeepsie, NY 12601 CPLteam.com NY ENGINEERING FIRM CERTIFICATE #018330


SHEL TEMPORARY RFB-[

No. Description

© TINKELMAN ARCHITECTURE PLLC | 2023 ALL RIGHTS RESERVED-COPY OR REPRODUCTION OF THIS DRAWIN PERMISSION OF THE ARCHITECT. UNAUTHORIZED ALTERATION OR ADDITION TO A DRAWING BEARING THE SEAL OF A LICENSED
ARCHITECT IS A VIOLATION OF SECTION 7209 SUBDIVISION 2 OF THE



33 Arlington Avenue, 2nd Floor, Poughkeepsie, NY 845.473.0200 | view our work at tinkarch.com



SECOND FLOOR MECHANICAL **NEW WORK** PLAN

C2349.00 01/18/2024

H-202

KEY PLAN SCALE: NTS