

PARTIAL NEW WORK SINGLE LINE DIAGRAM E900 NOT TO SCALE

WIRING LEGEND:

existing	
DEMO	
NEW	

GENERAL NOTES:

- A. THE CONTRACTOR MUST DEVELOP A SHUTDOWN SCHEDULE AND PROVIDE TO OWNER PRIOR TO ANY SHUTDOWNS. SHUTDOWN SCHEDULE MAY BE MODIFIED/CHANGED BY THE OWNER PRIOR TO ACTUAL SHUTDOWN.
- B. EQUIPMENT, BREAKERS, AND FEEDERS LABELED AS "(E)" ARE EXISTING TO
- C. ALL EXISTING AND NEW PANELBOARDS AFFECTED BY CONSTRUCTION SHALL HAVE UPDATED TYPED CIRCUIT DIRECTORIES. CIRCUITS SHALL BE FIELD TRACED TO UPDATE DIRECTORY AND VERIFY LOADS. PLACE ALL EXISTING AND NEWLY SPARED BREAKERS IN OFF POSITION AND LABEL AS "SPARE"

	PANEL: LPL-1B														
	LOCATION: ELECTRIC ROOM	SHORT CIRCUIT CURRENT: 10kAIC													
	VOLTAGE: 208Y/120V-3Ф-4W	MAIN CIRCUIT BREAKER: 225A													
FED FROM: MDP VIA T-1B XFRM					MAIN BUS: 225A										
	MOUNTING: SURFACE														
# LOAD DESCRIPTION A			Р	A (\	/A)	A) B (VA)			C (VA)		Α	LOAD DESCRIPTION	BKR	#	
11	RECPEPTACLE: LAUNDRY 113 WASHER	20 1 670 900		, 0	(17.4)		20	RECEPTACLE: WOMEN 201	DIXIX	2					
3	RECEPTACLE: CODE BLUE 116 WASHER	20	1	670	700	670	900			1	20	RECEPTACLE: MEN 207		4	
5	RECEPTACLE: 104Q WASHER	20	1			070	700	670	1200	1	20	RECEPTACLE: KITCHEN REFRIGERATOR		6	
7	RECEPTACLE: WOMEN 201 WASHER	20	1	670	960			0,0	1200	1	20	RECEPTACLE: KITCHEN FREEZER		8	
9	RECEPTACLE: WOMEN 201 WASHER	20	1	0.0	, 55	670	180			1	20	RECEPTACLE: KITCHEN		10	
11	RECEPTACLE: MEN 207 WASHER	20	1					670	180	1	20	RECEPTACLE: KITCHEN		12	
13	RECEPTACLE MEN 207 WASHER	20	1	670	180					1	20	RECEPTACLE: KITCHEN		14	
15						2375	180			1	20	RECEPTACLE: KITCHEN		16	
17	RECEPTACLE: LAUNDRY 113 DRYER	30	2					2375	1875					18	
19		30		2375	1875					2	30	RECEPTACLE: KITCHEN STEAM TABLE	GFCI	20	
21	RECEPTACLE: CODE BLUE 116 DRYER		2			2375	1000			1	20	RECEPTACLE: ADMIN COPIER		22	
23	RECEPTACLE: 104Q DRYER	20						2375	1000	1	20	RECEPTACLE: ADMIN COPIER		24	
25		30	2	2375	900					1	20	RECEPTACLE: LOUNGE REFRIGERATOR		26	
27	RECEPTACLE: WOMEN 201 DRYER					2375	180			1	20	RECEPTACLE: KITCHEN		28	
29			2					2375	180	1	20	RECEPTACLE: BREAK ROOM COUNTER		30	
31	RECEPTACLE: WOMEN 201 DRYER	30	2	2375	180					1	20	RECEPTACLE: BREAK ROOM COUNTER		32	
33	MEGET MOLE. MOMEN 201 DIVIEN					2375	0			1	20	SPARE		34	
35	- RECEPTACLE: MEN 207 DRYER	30	2					2375	0	1	20	SPARE		36	
37	ALOCI MOLL, MEN 207 DIVIER		_	2375	0					1	20	SPARE		38	
39	RECEPTACLE: MEN 207 DRYER	30	2			2375	0			1	20	SPARE		40	
41								2375	0	1	20	SPARE		42	
	TOTA	- AMI	PS:	13	7	13	0	14	7						
TOTAL LOAD (VA):				16505		15655		17650							

LUMINAIRE SCHEDULE										
MARK	DESCRIPTION	MANUFACTURER	MODEL	VOLTAGE	LOAD (W)	REMARKS				
L1	2'X4' RECESSED LED FLAT PANEL WITH WHITE FINISH, 0-10V DIMMING, SELECTABLE LUMEN AND CCT OUTPUT	DAY-BRITE CFI	2SBP3550L8CS-4-UNV-DIM	120-277V	50	1				
W1	EXTERIOR LED WALL PACK WITH BLACK FINISH, TYPE 4 DISTRIBUTION, BI-LEVEL FUNCTIONALITY, MOTION SENSOR, AND PHOTOCELL	STONCO	LPW32-70-NW-G3-4-277-BL-IMRI3-PCB-BK	277V	70	2				
X1	UNIVERSAL MOUNT LED EXIT SIGN WITH CRS HOUSING, WHITE FINISH, AND RED LETTERING	CHLORIDE	EXL3RW	120-277V	3.8	3				

A. PROVIDE ALL MOUNTING BRACKETS AND ACCESSORIES AS NECESSARY FOR INSTALLATION OF FIXTURE.

REMARKS:

- FIXTURE CONTAINS SWITCHABLE LUMEN AND CCT TECHNOLOGY. CONTRACTOR SHALL FIELD SET CCT TO MATCH FIXTURES IN AREA AND SET LUMEN LEVEL TO HIGHEST OUTPUT. PROVIDE PROJECT WITH (1) REMOTE FOR PROGRAMMING. PROGRAM FIXTURE TO DIM TO 50% OUTPUT WHEN NO OCCUPANCY IS DETECTED FOR 15 MINUTES.
- 3. PROVIDE NUMBER OF FACES AND CHEVRON DIRECTIONS AS INDICATED ON E300 SERIES DRAWINGS.



SHEL Y HOMELESS (3-DCB-01-24 TEMPORARY RFB-[

No. Description

© TINKELMAN ARCHITECTURE PLLC | 2023 PERMISSION OF THE ARCHITECT. UNAUTHORIZED ALTERATION OR ADDITION TO A DRAWING BEARING THE SEAL OF A LICENSED
ARCHITECT IS A VIOLATION OF SECTION 7209 SUBDIVISION 2 OF THE





ELECTRICAL SCHEDULES AND PARTIAL ONE-LINE DIAGRAM C2349.00

01/18/2024

E900