

**SECTION 210500  
COMMON WORK RESULTS FOR FIRE SUPPRESSION**

**PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Above ground piping.
- B. Escutcheons.
- C. Mechanical couplings.
- D. Pipe hangers and supports.
- E. Pipe sleeves.
- F. Pipe sleeve-seal systems.

**1.02 RELATED REQUIREMENTS**

- A. Section 078400 - Firestopping.
- B. Section 211300 - Fire-Suppression Sprinkler Systems: Sprinkler systems design.

**1.03 REFERENCE STANDARDS**

- A. ASME A112.18.1 - Plumbing Supply Fittings 2018, with Errata.
- B. ASME BPVC-IX - Boiler and Pressure Vessel Code, Section IX - Qualification Standard for Welding, Brazing, and Fusing Procedures; Welders; Brazers; and Welding, Brazing, and Fusing Operators 2021.
- C. ASME B16.1 - Gray Iron Pipe Flanges and Flanged Fittings: Classes 25, 125, and 250 2020.
- D. ASME B16.3 - Malleable Iron Threaded Fittings: Classes 150 and 300 2021.
- E. ASME B16.4 - Gray Iron Threaded Fittings: Classes 125 and 250 2021.
- F. ASME B16.5 - Pipe Flanges and Flanged Fittings: NPS 1/2 through NPS 24 Metric/Inch Standard 2020.
- G. ASTM A47/A47M - Standard Specification for Ferritic Malleable Iron Castings 1999, with Editorial Revision (2022).
- H. ASTM A53/A53M - Standard Specification for Pipe, Steel, Black and Hot-Dipped, Zinc-Coated, Welded and Seamless 2022.
- I. ASTM A135/A135M - Standard Specification for Electric-Resistance-Welded Steel Pipe 2021.
- J. ASTM A536 - Standard Specification for Ductile Iron Castings 1984, with Editorial Revision (2019).
- K. ASTM A795/A795M - Standard Specification for Black and Hot-Dipped Zinc-Coated (Galvanized) Welded and Seamless Steel Pipe for Fire Protection Use 2021.
- L. AWWA C606 - Grooved and Shouldered Joints 2015.
- M. NFPA 13 - Standard for the Installation of Sprinkler Systems Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide manufacturer's catalog information. Indicate valve data and ratings.
- C. Shop Drawings: Indicate pipe materials used, jointing methods, supports, and floor and wall penetration seals. Indicate installation, layout, weights, mounting and support details, and piping connections.
- D. For new and substantially modified sprinkler systems, drawings and hydraulic calculations are required to be submitted. Plans and calcs must be stamped by a Professional Engineer (PE) licensed in the State of the project or NICET level designer. Drawings and calculations must be submitted to the Local Building Department as part of the Project Building Permit.

- E. Manufacturer's qualification statement.
- F. Installer's qualification statement.
- G. Project Record Documents: Record actual locations of components and tag numbering.
- H. Operation and Maintenance Data: Include installation instructions and spare parts lists.

### **1.05 QUALITY ASSURANCE**

- A. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- B. Installer Qualifications: Company specializing in performing work of the type specified in this section.
  - 1. Minimum three years experience.
- C. Products Requiring Electrical Connection: Listed and classified as suitable for the purpose specified and indicated.

### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Deliver and store valves in shipping containers, with labeling in place.
- B. Provide temporary end caps and closures on piping and fittings. Maintain in place until installation.

### **1.07 WARRANTY**

- A. See Section 017800 - Closeout Submittals for additional warranty requirements.

## **PART 2 PRODUCTS**

### **2.01 GENERAL REQUIREMENTS**

- A. Sprinkler-based System:
  - 1. Comply with NFPA 13.
  - 2. See Section 211300.
- B. Welding Materials and Procedures: Comply with ASME BPVC-IX.
- C. Provide system pipes, fittings, sleeves, escutcheons, seals, and other related accessories.

### **2.02 ABOVE GROUND PIPING**

- A. Steel Pipe: ASTM A795 Schedule 10, ASTM A53 Schedule 40, ASTM A135/A135M Schedule 10, or ASTM A795 Schedule 40, black.
  - 1. Steel Fittings: ASME B16.5 steel flanges and fittings.
  - 2. Cast Iron Fittings: ASME B16.1, flanges and flanged fittings and ASME B16.4, threaded fittings.
  - 3. Malleable Iron Fittings: ASME B16.3, threaded fittings and ASTM A47/A47M.
  - 4. Mechanical Grooved Couplings: Malleable iron housing clamps to engage and lock, "C" shaped elastomeric sealing gasket, steel bolts, nuts, and washers; galvanized for galvanized pipe.
  - 5. Mechanical Formed Fittings: Carbon steel housing with integral pipe stop and O-ring pocked and O-ring, uniformly compressed into permanent mechanical engagement onto pipe.

### **2.03 ESCUTCHEONS**

- A. Manufacturers:
  - 1. Fire Protection Products, Inc: [www.fppi.com/#sle.com/#sle](http://www.fppi.com/#sle.com/#sle).
  - 2. Tyco Fire Protection Products: [www.tyco-fire.com/#sle](http://www.tyco-fire.com/#sle).
  - 3. Viking Group Inc: [www.vikinggroupinc.com/#sle](http://www.vikinggroupinc.com/#sle).
  - 4. Substitutions: See Section 016000 - Product Requirements.
- B. Material:
  - 1. Metals and Finish: Comply with ASME A112.18.1.
- C. Construction:

1. One-piece for mounting on chrome-plated tubing or pipe and one-piece or split-pattern type elsewhere.
2. Internal spring tension devices or setscrews to maintain a fixed position against a surface.

#### **2.04 PIPE HANGERS AND SUPPORTS**

- A. Hangers for Pipe Sizes 1/2 to 1-1/2 inch (15 to 40 mm): Malleable iron, adjustable swivel, split ring.
- B. Hangers for Pipe Sizes 2 inches (50 mm) and Over: Carbon steel, adjustable, clevis.

#### **2.05 MECHANICAL COUPLINGS**

- A. Manufacturers:
  1. Anvil International: [www.anvilintl.com/#sle](http://www.anvilintl.com/#sle).
  2. Shurjoint Piping Products, Inc: [www.shurjoint.com/#sle](http://www.shurjoint.com/#sle).
  3. Tyco Fire Protection Products: [www.tyco-fire.com/#sle](http://www.tyco-fire.com/#sle).
  4. Victaulic Company; FireLock Style 009H: [www.victaulic.com/#sle](http://www.victaulic.com/#sle).
- B. Rigid Mechanical Couplings for Grooved Joints:
  1. Dimensions and Testing: Comply with AWWA C606.
  2. Minimum Working Pressure: 300 psig (2065 kPa).
  3. Housing Material: Fabricate of ductile iron complying with ASTM A536.
  4. Housing Coating: Factory applied orange enamel.
  5. Gasket Material: EPDM suitable for operating temperature range from minus 30 degrees F (minus 34 degrees C) to 230 degrees F (110 degrees C).
  6. Bolts and Nuts: Hot-dipped-galvanized or zinc-electroplated steel.

### **PART 3 EXECUTION**

#### **3.01 PREPARATION**

- A. Ream pipe and tube ends. Remove burrs. Bevel plain end ferrous pipe.
- B. Remove scale and foreign material, from inside and outside, before assembly.
- C. Prepare piping connections to equipment with flanges or unions.

#### **3.02 INSTALLATION**

- A. Install sprinkler system and service main piping, hangers, and supports in accordance with NFPA 13.
- B. Route piping in orderly manner, plumb and parallel to building structure. Maintain gradient.
- C. Install piping to conserve building space, to not interfere with use of space and other work.
- D. Group piping whenever practical at common elevations.
- E. Install piping to allow for expansion and contraction without stressing pipe, joints, or connected equipment.
- F. Fire suppression piping shall be independently supported and nothing else may touch or be supported by fire suppression piping and/or associated hangers/supports.
- G. Pipe Hangers and Supports:
  1. Install hangers to provide minimum 1/2 inch (15 mm) space between finished covering and adjacent work.
  2. Place hangers within 12 inches (300 mm) of each horizontal elbow.
  3. Use hangers with 1-1/2 inch (40 mm) minimum vertical adjustment. Design hangers for pipe movement without disengagement of supported pipe.
  4. Support vertical piping at every other floor. Support riser piping independently of connected horizontal piping.
  5. Where several pipes can be installed in parallel and at same elevation, provide multiple or trapeze hangers.
- H. Slope piping and arrange systems to drain at low points. Use eccentric reducers to maintain top of pipe level.

- I. Prepare pipe, fittings, supports, and accessories for finish painting. Where pipe support members are welded to structural building framing, scrape, brush clean, and apply one coat of zinc-rich primer to welding.
- J. Structural Considerations:
  - 1. Do not penetrate building structural members unless indicated.
- K. Provide sleeves when penetrating footings, floors, walls, and partitions. Seal pipe including sleeve penetrations to achieve fire resistance equivalent to fire separation required.
- L. Escutcheons:
  - 1. Install and firmly attach escutcheons at piping penetrations into finished spaces.
  - 2. Provide escutcheons on both sides of partitions separating finished areas through which piping passes.
  - 3. Use chrome plated escutcheons in occupied spaces and to conceal openings in construction.
- M. When installing more than one piping system material, ensure system components are compatible and joined to ensure the integrity of the system. Provide necessary joining fittings. Ensure flanges, unions, and couplings for servicing are consistently provided.
- N. Perform all pressure tests as required by NFPA 13.

### **3.03 CLEANING**

- A. Upon completion of work, clean all parts of the installation.
- B. Clean equipment, pipes, valves, and fittings of grease, metal cuttings, and sludge that may have accumulated from the installation and testing of the system.
- C. See Section 017419 - Construction Waste Management and Disposal for additional requirements.

**END OF SECTION 210500**

**SECTION 210553  
IDENTIFICATION FOR FIRE SUPPRESSION PIPING AND EQUIPMENT****PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Nameplates.
- B. Tags.
- C. Pipe markers.

**1.02 RELATED REQUIREMENTS**

- A. Section 099123 - Interior Painting: Stencil paint.

**1.03 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements, for submittal procedures.
- B. Chart and Schedule: Submit valve chart and schedule, including valve tag number, location, function, and valve manufacturer's name and model number.
- C. Product Data: Provide manufacturers catalog literature for each product required.
- D. Manufacturer's Installation Instructions: Indicate special procedures, and installation instructions.

**PART 2 PRODUCTS****2.01 IDENTIFICATION APPLICATIONS**

- A. Major Control Components: Nameplates.
- B. Piping: Tags.

**2.02 NAMEPLATES**

- A. Description: Laminated three-layer plastic with engraved letters.
  - 1. Letter Color: White.
  - 2. Letter Height: 1/4 inch (6 mm).
  - 3. Background Color: Black.

**2.03 TAGS**

- A. Metal Tags: Brass with stamped letters; tag size minimum 1-1/2 inch (40 mm) diameter with smooth edges.

**2.04 PIPE MARKERS**

- A. Color: Comply with ASME A13.1.
- B. Plastic Pipe Markers: Factory fabricated, flexible, semi-rigid plastic, preformed to fit around pipe or pipe covering; minimum information indicating flow direction arrow and identification of fluid being conveyed.

**PART 3 EXECUTION****3.01 PREPARATION**

- A. Degrease and clean surfaces to receive adhesive for identification materials.
- B. Prepare surfaces in accordance with Section 099123 for stencil painting.

**3.02 INSTALLATION**

- A. Install nameplates with corrosive-resistant mechanical fasteners, or adhesive. Apply with sufficient adhesive to ensure permanent adhesion and seal with clear lacquer.
- B. Install tags with corrosion resistant chain.
- C. Install plastic pipe markers in accordance with manufacturer's instructions.
- D. Use tags on piping 3/4 inch (20 mm) diameter and smaller.
- E. Pipe markers shall be installed as follows:

1. Identify service, flow direction, and pressure.
2. Install in clear view and align with axis of piping.
3. Locate identification not to exceed 20 feet (6 m) on straight runs including risers and drops, adjacent to each valve and Tee, at each side of penetration of structure or enclosure, and at each obstruction.

**END OF SECTION 210553**

**SECTION 211300  
FIRE-SUPPRESSION SPRINKLER SYSTEMS****PART 1 GENERAL****1.01 SECTION INCLUDES**

- A. Wet-pipe sprinkler system.
- B. Dry-pipe sprinkler system.
- C. System design, installation, and certification.

**1.02 REFERENCE STANDARDS**

- A. ICC-ES AC308 - Acceptance Criteria for Post-Installed Adhesive Anchors in Concrete Elements 2023.
- B. NFPA 13 - Standard for the Installation of Sprinkler Systems Most Recent Edition Adopted by Authority Having Jurisdiction, Including All Applicable Amendments and Supplements.
- C. UL (DIR) - Online Certifications Directory Current Edition.

**1.03 ADMINISTRATIVE REQUIREMENTS**

- A. Preinstallation Meeting: Convene one week before starting work of this section.

**1.04 SUBMITTALS**

- A. See Section 013000 - Administrative Requirements for submittal procedures.
- B. Product Data: Provide data on sprinklers, valves, and specialties, including manufacturers catalog information. Submit performance ratings, rough-in details, weights, support requirements, and piping connections.
- C. Shop Drawings:
  - 1. Submit preliminary layout of finished ceiling areas indicating only sprinkler locations coordinated with ceiling installation.
  - 2. Indicate hydraulic calculations, detailed pipe layout, hangers and supports, sprinklers, components, and accessories. Indicate system controls.
  - 3. Submit shop drawings, product data, and hydraulic calculations to Authorities Having Jurisdiction for approval. Submit proof of approval to Architect.
- D. Manufacturer's Certificate: Certify that system has been tested and meets or exceeds specified requirements and code requirements.
- E. Manufacturer's qualification statement.
- F. Installer's qualification statement.
- G. Operation and Maintenance Data: Include components of system, servicing requirements, record drawings, inspection data, replacement part numbers and availability, and location and numbers of service depot.
- H. Maintenance Materials: Furnish the following for Owner's use in maintenance of project.
  - 1. See Section 016000 - Product Requirements for additional provisions.
  - 2. Extra Sprinklers: Type and size matching those installed in quantity required by referenced NFPA design and installation standard.
  - 3. Sprinkler Wrenches: For each sprinkler type.
- I. Project Record Documents: Record actual locations of sprinklers and deviations of piping from drawings. Indicate drain and test locations.

**1.05 QUALITY ASSURANCE**

- A. Maintain one copy of referenced design and installation standard on site.
- B. Comply with FM (AG) requirements.
- C. Designer Qualifications: Design system under direct supervision of a Professional experienced in design of this type of work and licensed in the State in which the Project is located.

- D. Manufacturer Qualifications: Company specializing in manufacturing the Products specified in this section with minimum three years documented experience.
- E. Installer Qualifications: Company specializing in performing the work of this section with minimum 3 years experience and approved by manufacturer.
- F. Equipment and Components: Provide products that bear FM (AG) label or marking.
- G. Products Requiring Electrical Connection: Listed and classified by UL (DIR) as suitable for the purpose specified and indicated.

#### **1.06 DELIVERY, STORAGE, AND HANDLING**

- A. Store products in shipping containers and maintain in place until installation. Provide temporary inlet and outlet caps. Maintain caps in place until installation.

### **PART 2 PRODUCTS**

#### **2.01 MANUFACTURERS**

- A. Sprinklers, Valves, and Equipment:
  - 1. Anvil International: [www.anvilintl.com/#sle](http://www.anvilintl.com/#sle).
  - 2. Tyco Fire Protection Products: [www.tyco-fire.com/#sle](http://www.tyco-fire.com/#sle).
  - 3. Viking Corporation: [www.vikinggroupinc.com/#sle](http://www.vikinggroupinc.com/#sle).
  - 4. Reliable.
  - 5. Substitutions: See Section 016000 - Product Requirements.

#### **2.02 SPRINKLER SYSTEM**

- A. Sprinkler System: Provide coverage for building areas noted.
- B. Occupancy: Ordinary hazard, Group 1; comply with NFPA 13. See drawings for design criteria.
- C. Water Supply: Determine volume and pressure from water flow test data. Contractor to perform new flow test prior to submitting hydraulic calculations.
- D. Interface system with building fire and smoke alarm system.
- E. Storage Cabinet for Spare Sprinklers and Tools: Steel, located adjacent to alarm valve.
- F. Pipe Hanger Fasteners: Attach hangers to structure using appropriate fasteners, as follows:
  - 1. Masonry Wedge Expansion Anchors: Complying with ICC-ES AC01.
  - 2. Concrete Screw Type Anchors: Complying with ICC-ES AC193.
  - 3. Concrete Adhesive Type Anchors: Complying with ICC-ES AC308.

#### **2.03 SPRINKLERS**

- A. Suspended Ceiling Type: Concealed pendant type with matching push on escutcheon plate. See drawings for sprinkler head description.
  - 1. Response Type: Quick.
  - 2. Coverage Type: Standard.
  - 3. Finish: Enamel, color White .
  - 4. Fusible Link: Fusible solder link type temperature rated for specific area hazard.
  - 5. Manufacturers:
    - a. Tyco Fire Protection Products: [www.tyco-fire.com/#sle](http://www.tyco-fire.com/#sle).
- B. Flexible Drop System: Stainless steel, multiple use, open gate type.
  - 1. Application: Use to properly locate sprinkler heads.
  - 2. Include all supports and bracing.
  - 3. Provide braided type tube as required for the application.
  - 4. Manufacturers:
    - a. FlexHead Industries, a brand of Anvil International: [www.anvilintl.com/#sle](http://www.anvilintl.com/#sle).
    - b. Victaulic Company; Vic-Flex: [www.victaulic.com/#sle](http://www.victaulic.com/#sle).

#### **2.04 PIPING SPECIALTIES**

- A. Test Connections:



1. Inspector's Test Connection:
  - a. Route test connection to an janitor sink, accepting full flow without negative consequences.

**PART 3 EXECUTION**

**3.01 INSTALLATION**

- A. Install in accordance with referenced NFPA design and installation standard.
- B. Install equipment in accordance with manufacturer's instructions.
- C. Place pipe runs to minimize obstruction to other work.
- D. Place piping in concealed spaces above finished ceilings.
- E. Center sprinklers in two directions in ceiling tile and provide piping offsets as required.
- F. Apply masking tape or paper cover to ensure concealed sprinklers, cover plates, and sprinkler escutcheons do not receive field paint finish. Remove after painting. Replace painted sprinklers.
- G. Flush entire piping system of foreign matter.
- H. Hydrostatically test entire system.
- I. Require test be witnessed by Fire Marshal.

**3.02 INTERFACE WITH OTHER PRODUCTS**

- A. Ensure required devices are installed and connected as required to fire alarm system.

**3.03 SCHEDULES**

- A. System Hazard Areas:
  1. Offices: Light Hazard.
  2. Warehouse, Mechanical, Storage rooms: Ordinary Hazard, Group 2.

**END OF SECTION 211300**

This page intentionally left blank