



FREDERICK W. SEEBA, PE, MANAGING PARTNER  
LAWRENCE SALVESEN, AIA, PARTNER  
KEVIN J. WALSH, AIA, PARTNER  
KENNETH G. SCHUPNER, AIA, PARTNER  
JOSEPH B. RETTIG, AIA, PARTNER  
GARY W. SCHIEDE, AIA, PARTNER  
ROGER P. SMITH, AIA, FOUNDING PRINCIPAL

February 12, 2026

**CLARIFICATION No. 1**

Re: Bedford CSD  
Phase 2a – Bond Improvements at  
Maintenance Building  
South Bedford Road  
Bedford, NY 10506  
SED No.66-01-02-06-5-027-001  
BBS File No. 23-131k

This addendum contains changes to the requirements of the contract drawings and/or project manual. Such changes shall be incorporated into the contract documents and shall apply to the work with the same meaning and force as if they had been included in the original documents. Wherever this addendum modifies a portion of a paragraph of project manual or any portion of the drawing, the remainder of the paragraph or drawing affected shall remain in force.

The conditions of the basic project manual shall govern all work described in this addendum. Wherever the conditions of work and the quality or quantity of materials or workmanship are not fully described in this addendum, the conditions of work, etc. included in the basic project manual for similar items of work shall apply to the work described in this addendum.

The "Conditions of the Contract" apply to all work described in this addendum.

The following changes shall be and are hereby made:

**CLARIFICATIONS**

- 1. Please be aware that the Milestone Schedule is to follow the specified metal building or approved equal product availability.**
- 2. In the event that rock removal is required at the perimeter Footing/Foundation location the minimum depth shall be no less than 4'-0" below the adjacent grade. A pin to rock detail will be provided for depths greater than 4'-0" if necessary.**

**END OF ADDENDUM**