



# AIA<sup>®</sup> Document G716<sup>™</sup> – 2004

## Request for Information (“RFI”)

**TO:**

Brian T. Dunn, AIA  
KG+D Architects, PC  
285 Main Street  
Mount Kisco, NY 10549

**PROJECT:**

Harrison, Town-Village Recreation Center Phase 2  
270 Harrison Avenue  
Harrison, NY 10528

**FROM:**

S. MCCABE/P. DOLSON  
LJ Coppola  
40 Farrington Road  
Brewster, NY 10509

**ISSUE DATE:****RFI No.**

#007

**PROJECT NUMBERS:** 2020-1005 /**REQUESTED REPLY DATE:****COPIES TO:****RFI DESCRIPTION:** *(Fully describe the question or type of information requested.)*

The gas service cannot enter the building underground as shown on P-201; please provide an alternate route, as well as additional information regarding the exterior piping, meter, and connection location.

**REFERENCES/ATTACHMENTS:** *(List specific documents researched when seeking the information requested.)***SPECIFICATIONS:****DRAWINGS:**

P-201 - (PARKING FLOOR)

**OTHER:**

**SENDER'S RECOMMENDATION:** *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

**RECEIVER'S REPLY:** *(Provide answer to RFI, including cost and/or schedule considerations.)*

Piazza Inc

12/10/2024

**BY****DATE****COPIES TO**

**Note:** This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

**OLA Response 01-13-2025:**

Con Edison gas meter shall be located between column lines A.8 and B.8 along exterior wall. Natural gas pipe shall penetrate exterior wall at that location above grade so that piping is routed in garage, and then shall be routed to gas booster pump in mechanical room. Plumbing Contractor shall coordinate with Con Edison and shall open up gas case with them. Plumbing Contractor shall coordinate final location of gas meter rig with Architect.

Gas Rig will maintain 10' clearance with intake louver. Concrete pad per Con Ed requirements.  
Bulletin for gas service relocation to be issued. KGD 01/13/245