



# AIA<sup>®</sup> Document G716<sup>™</sup> – 2004

## Request for Information (“RFI”)

**TO:**

Brian T. Dunn, AIA  
KG+D Architects, PC  
285 Main Street  
Mount Kisco, NY 10549

**FROM:**

PIAZZA INC  
PHIL PIGNATELLI

**PROJECT:**

Harrison, Town-Village Recreation Center Phase 2  
270 Harrison Avenue  
Harrison, NY 10528

**ISSUE DATE:** 12/11/24**RFI No.** ~~01~~ = 008**PROJECT NUMBERS:** 2020-1005 /**REQUESTED REPLY DATE:**  
**COPIES TO:****RFI DESCRIPTION:** *(Fully describe the question or type of information requested.)*

. There is no detail for the 6" step in slab elevation change. Usually there would be a haunch.

**REFERENCES/ATTACHMENTS:** *(List specific documents researched when seeking the information requested.)***SPECIFICATIONS:****DRAWINGS:****OTHER:****SENDER'S RECOMMENDATION:** *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)***RECEIVER'S REPLY:** *(Provide answer to RFI, including cost and/or schedule considerations.)***Brian Dunn****2025-01-15****BY****DATE****COPIES TO**

**Note:** This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

Please see 1/S201 slab details for the stepped slab detail. The step can be up to 9" differential between the two slabs. If a greater than 9" delta is found please notify Architect.