



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

FROM:

Piazza Inc

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

ISSUE DATE:

1/9/2025

RFI No.

~~005~~
#019

PROJECT NUMBERS: 2020-1005 /

REQUESTED REPLY DATE:

COPIES TO:

RFI DESCRIPTION: *(Fully describe the question or type of information requested.)*

We would like for a review of modifying the elevator door opening to the right side in an effort not to have to move the existing Sump pump pit

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS:

DRAWINGS:

OTHER:

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

Door to be re-located per the coordination meeting with the Elevator mfc. KGD to revise the closet size to accommodate the elevator equipment and door.

BY Brian Dunn

DATE 2025-02-03

COPIES TO

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.