## Request for Information ("RFI")

Brian T. Dunn, AIA KG+D Architects, PC 285 Main Street Mount Kisco, NY 10549 PROJECT:

Harrison, Town-Village Recreation Center Phase 2

270 Harrison Avenue Harrison, NY 10528 1/20/2025

Piazza Inc

RFI No. #02.1

#021

**PROJECT NUMBERS:** 2020-1005 /

REQUESTED REPLY DATE:

COPIES TO:

FROM:

**RFI DESCRIPTION**: (Fully describe the question or type of information requested.)

It was recently noted during underground piping layout, that the areaway drains appear to be tied into the building foundation drain. Please confirm that it is no longer necessary to connect these to the below slab drain piping to the duplex sump pump.

**SENDER'S RECOMMENDATION:** (If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)

**RECEIVER'S REPLY:** (Provide answer to RFI, including cost and/or schedule considerations.)

Phil Pignatelli	1/20/202	5		
BY	DATE		COPIES TO	

**Note:** This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

The area way drain pipes are to be disconnected from the abandoned foundation drain pipe. Please connect the drains to the drain piping to the sump as originally designed.

40 Farrington Road Brewster, NY 10509 (914) 769-7666 Fax: (914) 769-5141

Plumbing License No. 750

**PLUMBING** H.V.A.C. PROCESS PIPING SEWAGE TREATMENT ESTABLISHED 1972

## **REQUEST FOR INFORMATION**

		_	_			
Project: <u>HARRISON REC CENTE</u>	R PHASE 2	<b>Date</b> : <u>1/17/25</u>	Log No.: <u>LJC# -09</u>			
Drwg.: <u>P-200A</u>	Spec.: N/A	Area: AREAW	AY DRAINS			
Directed To: <u>PIAZZA BROTHERS</u>		Date	Required:			
Impact: SUB SLAB PIPING						
Regarding: <u>AREAWAY DRAIN C</u>	ONNECTIONS					
REQUESTED BY: S. MCCABE/P	. DOLSON cc:					
INFORMATION REQUIRED:						
It was recently noted during underground piping layout, that the areaway drains appear to be tied into the building foundation drain. Please confirm that it is no longer necessary to connect these to the below slab drain piping to the duplex sump pump.						
RESPONSE:						
RESPONSE BY:						
RESPONSE DATE:						

Your response is requested by the date listed above. Failure to respond by this date may delay the project schedule and may have a cost impact.



