AIA Document G716" - 2004

Request for Information ("RFI'7

TO:	FROM: Phil Pignatell1		
Brian T. Dunn, AIA			
KG+D Architects, PC			
285 Main Street			
Mount Kisco, NY 10549			
PROJECT:	ISSUE DATE: 02-06-25	RFI No.	029
Harrison, Town-Village Recreation Center Phase 2			
270 Harrison Avenue			
Harrison, NY 10528			
	REQUESTED REPLY DATE:		
PROJECT NUMBERS: 2020-1005 /	COPIES TO:		

RFIDESCRIPTION: Need an SK on how to attach fencing atop modular block wall

REFERENCES/ATTACHMENTS: (List specific documents researched when seeking the information requested.) SPECIFICATIONS: OTHER: DRAWINGS:

SENDER'S RECOMMENDATION: (If RF/ concerns a site or construction condition, the sender maypravide a recommended solution, including cost and/or schedule considerations.)

RECEIVER'S REPLY: (Provide answer to RF], including cost and/or schedule considerations.)

Please see 7/L100 for the fence post detail. At modular block wall with capstone set the fence post directly behind the capstone. Clarification of details, no scope increase related to this response.

Brian Dunn	2025-04-07	
BY	DATE	COPIES TO

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

1