



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

FROM:

Piazza Inc

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

ISSUE DATE:

2/17/2025

RFI No.

~~001~~

#034

REQUESTED REPLY DATE:**COPIES TO:**

PROJECT NUMBERS: 2020-1005 /

RFI DESCRIPTION: *(Fully describe the question or type of information requested.)*

See Attached

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS:

See Attached

DRAWINGS:

See Attached

OTHER:

See Attached

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

See Bulletin 4R for clarifications. Waterproofing is not required in the Parking Area.

Brian Dunn

BT

2025-03-14

DATE

COPIES TO

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

An error occurred!

Connection Error (Failed to reach the server)!

Settings

Webmail Home

Back Compose Reply Reply all Forward Delete Move Print Archive Mark More

Inbox

Drafts

Sent


Junk



Trash

Archive

RFI for Siteworks

Message 24 of 538



From **phil@piazabrothers.com** 
To **rj@piazabrothers.com** 
Date **Wed 15:30**

Below question from our subs on the new ASK, please advise.

- Please confirm where waterproofing shall be installed? Parking area or Mechanical Area or Both Locations?
- ASK-4/Detail 2:
 - please confirm if that detail pertains for entire basement or only at the Mech Room.
 - Please provide waterproofing (HENRY) termination detail.
 - Please confirm on what order waterproofing shall be installed (what above / what below). 2" of sand between the vapor barrier and geo fabric, and waterproofing?
- ASK-4 / detail 1:
 - Are we to remove all the stone and replace it with 6"-10" of Sand?
- Please confirm if underdrain pipe shall terminate at the Trench Drain or Detention System (plan shows to terminate at TD / Note Mention to Terminate at Detention System)., please provide invert elevation

Phil Pignatelli

Sr. Project Executive

Phil@Piazabrothers.com

973.632.7499