



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

FROM: Piazza Inc.**PROJECT:**

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

ISSUE DATE: 2/18/2025 **RFI No.** 038**REQUESTED REPLY DATE:**
COPIES TO:**PROJECT NUMBERS:** 2020-1005 /

RFI DESCRIPTION: *(Fully describe the question or type of information requested.)* Roof plan A204 (updated on 07/18/2024 in addendum #4) shows a different mechanical unit layout than the mechanical roof plan M-204 (updated 07/01/2024 in addendum #2). What is the correct mechanical unit layout to follow for installation of the new tapered insulation system?
Also, roof plan addendum #4 added in walkway roof pads around the mechanical layout per A204, if the mechanical layout from M-204 is to be followed additional walkway pads would need to be added.

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS:**DRAWINGS:** A204 & 3204**OTHER:**

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

BRIAN DUNN 2015-03-03

BY**DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

CONTRACTOR TO USE THE "ISSUED FOR CONSTRUCTION" SET DATED 2024-10-09 AND COORDINATE WITH THE MECHANICAL SHOP DRAWINGS FOR SIZES AND LOCATIONS OF EQUIPMENT. PROVIDE WALKWAY PADS IN ACCORDANCE WITH THE ISSUED FOR CONSTRUCTION SET.