



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

FROM:

Piazza Inc
3 W. Stevens Ave
Hawthorne, NY 10532

ISSUE DATE: 2/20/25**RFI No.** 039 - Nanawall SL45**REQUESTED REPLY DATE:** ASAP**COPIES TO:****PROJECT NUMBERS:** 2020-1005 /

RFI DESCRIPTION: In return Nanawall SL45 was rejected. In addendum #4, question #62 they stated the system werent required to be thermally broken, As we submitted the non thermally broken SL-45. If the SL-70 thermally broken frame is required, there will be a cost increase for the SL-70

REFERENCES/ATTACHMENTS: (List specific documents researched when seeking the information requested.)

SPECIFICATIONS: 083513**DRAWINGS:****OTHER:** Addendum#4

SENDER'S RECOMMENDATION: (If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)

RECEIVER'S REPLY: (Provide answer to RFI including cost and/or schedule considerations)

Submittal 083513 has been revised to "Make Corrections Noted." The SL45 is acceptable per Add #4.

BRIAN DUNN**2025-03-03****BY****DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.