



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

FROM: PIAZZA INC**PROJECT:**

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

ISSUE DATE: 03/14/2025**RFI No.** 048**REQUESTED REPLY DATE:****COPIES TO:****PROJECT NUMBERS:** 2020-1005 /**RFI DESCRIPTION:** *(Fully describe the question or type of information requested.)*

See pictures below.

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)***SPECIFICATIONS:****DRAWINGS:****OTHER:****SENDER'S RECOMMENDATION:** *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)***RECEIVER'S REPLY:** *(Provide answer to RFI, including cost and/or schedule considerations.)***BY****DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.

OLA Response: 03-26-2025:

Phase 1 Contractor was on site week of 04-17-2025 to rectify the geothermal well issues.

Design Team met with the Phase 1 Geothermal subcontractor to review the conditions. The subcontractor returned and placed additional grout in two wells to bring them up to the top of the well casing.

Brian Dunn 2015-03-26

Approximate location of hole apparently for geothermal system. please advise.

