



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

FROM:

Piazza Inc.
3 W. Stevens Ave
HAwthorne, NY 10532

ISSUE DATE: 03/25/2025**RFI No.** RFI 053 - 2nd Floor
Ceiling Changes**REQUESTED REPLY DATE:** ASAP**COPIES TO:****PROJECT NUMBERS:** 2020-1005 /**RFI DESCRIPTION:**


Per discussion during the 3/19/25 coordination meeting, it was noted that the 2nd floor ductwork will not fit in certain areas, and that the ceilings will need to be lowered appropriately. Please see the attached 2nd floor duct shop drawing with comments indicating the required changes for engineer and architect review.

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)***SPECIFICATIONS:****DRAWINGS:****OTHER:****SENDER'S RECOMMENDATION:** *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)***RECEIVER'S REPLY:** *(Provide answer to RFI, including cost and/or schedule considerations.)*

Based on the coordination meetings held with the design team and the contractors it is acceptable to lower the 2nd floor ceilings to 9'-4" AFF to align with the perimeter soffit.

Brian Dunn**2025-04-02****BY****DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.



L.J. COPPOLA INC.

MECHANICAL CONTRACTORS

40 Farrington Road
Brewster, NY 10509
(914) 769-7666
Fax: (914) 769-5141
Plumbing License No. 750

PLUMBING

H.V.A.C.

PROCESS PIPING

SEWAGE TREATMENT

ESTABLISHED 1972

REQUEST FOR INFORMATION

Project: HARRISON REC CENTER PHASE 2 **Date:** 3/25/25 **Log No.:** LJC# -06

Drwg.: N/A **Spec.:** N/A **Area:** 2ND FLOOR

Directed To: PIAZZA BROTHERS **Date Required:**

Impact: N/A

Regarding: CEILING HEIGHTS FOR DUCTWORK

REQUESTED BY: LJC/TACONIC **cc:**

INFORMATION REQUIRED:

Per discussion during the 3/19/25 coordination meeting, it was noted that the 2nd floor ductwork will not fit in certain areas, and that the ceilings will need to be lowered appropriately. Please see the attached 2nd floor duct shop drawing with comments indicating the required changes for engineer and architect review.

RESPONSE:

RESPONSE BY:

RESPONSE DATE: **cc:**

Your response is requested by the date listed above. Failure to respond by this date may delay the project schedule and may have a cost impact.

