



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

FROM:

Piazza Inc.
3 W. Stevens Ave
HAwthorne, NY 10532

ISSUE DATE: 03/31/2025**RFI No.** RFI - 055 Beam Pockets
& Elevator Door
Location**REQUESTED REPLY DATE:** ASAP**COPIES TO:****PROJECT NUMBERS:** 2020-1005 /

RFI DESCRIPTION: Please see the attached photos. 1. The elevator door opening is in the wrong location. 2. We are missing an opening between column lines A8 & B8; Piazza will need to sawcut the concrete and remove it. Please advise.

REFERENCES/ATTACHMENTS: (List specific documents researched when seeking the information requested.)

SPECIFICATIONS:**DRAWINGS:****OTHER:**

SENDER'S RECOMMENDATION: (If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)

The elevator door opening needs to be flipped to the north side of the shaft due to the location of the sump pit below.

Potential scope increase to widen the existing knockout for the elevator door and to infill with concrete on the south side. Approximately 1CY.

The beam pocket for the W14x22 at the location shown in the attached photo is shown on S101 of the Bid set dated 2024-06-05, attached.
Included in original scope for Phase 2

Brian Dunn**2025-04-02****BY****DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.



