



AIA[®] Document G716[™] – 2004

Request for Information (“RFI”)

TO:

Brian T. Dunn, AIA
KG+D Architects, PC
285 Main Street
Mount Kisco, NY 10549

PROJECT:

Harrison, Town-Village Recreation Center Phase 2
270 Harrison Avenue
Harrison, NY 10528

FROM:

Piazza Inc.
3 W. Stevens Ave
HAwthorne, NY 10532

ISSUE DATE: 04/03/2025**RFI No.** 059 - Blueskin**REQUESTED REPLY DATE:** ASAP**COPIES TO:****PROJECT NUMBERS:** 2020-1005 /

RFI DESCRIPTION: As discussed this morning with Mike Comerford, please confirm that there's no termination details for the blueskin. Also confirm that the 2" coverage is acceptable over the 4" conduit laying on the blueskin at the mechanical room.

REFERENCES/ATTACHMENTS: *(List specific documents researched when seeking the information requested.)*

SPECIFICATIONS:**DRAWINGS:****OTHER:**

SENDER'S RECOMMENDATION: *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

RECEIVER'S REPLY: *(Provide answer to RFI, including cost and/or schedule considerations.)*

The above description of the Blueskin installation is confirmed. The 2" coverage at the electrical conduits is acceptable in the locations south of column line D.1. The Parking area to maintain full concrete coverage.

Brian Dunn**2025-04-03****BY****DATE****COPIES TO**

Note: This reply is not an authorization to proceed with work involving additional cost, time or both. If any reply requires a change to the Contract Documents, a Change Order, Construction Change Directive or a Minor Change in the work must be executed in accordance with the Contract Documents.