



# AIA<sup>®</sup> Document G716<sup>™</sup> – 2004

## Request for Information (“RFI”)

---

**TO:**

Brian T. Dunn, AIA  
KG+D Architects, PC  
285 Main Street  
Mount Kisco, NY 10549

**PROJECT:**

Harrison, Town-Village Recreation Center Phase 2  
270 Harrison Avenue  
Harrison, NY 10528

**FROM:**

Piazza Inc.  
3 W. Stevens Ave  
HAwthorne, NY 10532

**ISSUE DATE:** 04/09/2025**RFI No.** RFI 063 - Questions on  
heels of Post Sub RFI1**REQUESTED REPLY DATE:** ASAP  
**COPIES TO:****PROJECT NUMBERS:** 2020-1005 /

---

**RFI DESCRIPTION:** See attached from Director Door Ind.**REFERENCES/ATTACHMENTS:** *(List specific documents researched when seeking the information requested.)***SPECIFICATIONS:****DRAWINGS:****OTHER:****SENDER'S RECOMMENDATION:** *(If RFI concerns a site or construction condition, the sender may provide a recommended solution, including cost and/or schedule considerations.)*

---

**RECEIVER'S REPLY:** *(Provide answer to RFI, including cost and/or schedule considerations.)*

1-113M is in a type M8 wall without furring. 113M to be jamb depth of 8 3/4" as indicated on A202. 113A and 113B is in a type M8 wall with furring on the south side. The furring wall will be constructed after the masonry wall is in place. Therefore, place the frames for 113A and 113B in the masonry wall type M8 with an 8 3/4" jamb depth as indicated on A202. The furred out portion of the wall will align with the masonry openings. The tile finish to die into the jamb.

2- Contractor to provide the requested template.

3- The 5/8" dimension is inclusive of the setting material.

3a- The slate saddle will apply to conditions where we are separating the sports floor from porcelain tile only. Doors where the sports floor transitions to sports flooring and all other flooring types will be aluminum. Please refer to sheet A502 for floor types. Doors 113A, B, D, and M to receive the slate saddle. Doors 113C,E,F,J,K, and L to receive the aluminum saddle. Doors 113G and H are exterior doors with aluminum thresholds.

This response constitutes a clarification of the Contract Documents and does not represent an increase in project scope.

NOV 01 2025 11:11 AM. This document, which expires on 04/21/2024, is not for resale, is licensed for one-time use only, and may only be used in accordance with the AIA Contract Documents® Terms of Service. To report copyright violations, e-mail docinfo@aiacontracts.com.

**User Notes:**

(3B9ADA55)



6 Commercial Street Hicksville, NY 11801

(T) 631-777-7878



**Post Submittal RFI #2  
Harrison R&C Center  
Job #300799**

April 9, 2025

Post Submittal RFI #2

---

1. **Please Advise:** Post Sub RFI #1 response states to use the Type C wall for tags 113A, 113B, & 113M. Remarks also state to use a 5  $\frac{3}{4}$ " jamb depth for Type C walls. However, the jamb depth schedule at the end of the RFI shows these tags with an 8  $\frac{3}{4}$ " jamb depth. Please advise which to use, we assume 5  $\frac{3}{4}$ "
2. **Please Provide:** the door contact template being used by security vendor so Director Door can prep accordingly. This remains as we have yet to receive.
3. **Please Note:** Per previous RFI, gym sill conditions were changed to 4C/A911. This shows a slate saddle by others. Remarks state saddle is 5/8" high. Please confirm this includes the mud or adhesive used or there is additional height to include.
  - a. We assume this new sill condition applies to tags 113A, 113B, & 113D. Please advise if tags 113E, 113F, 113J, 113K, 113L, & 113M should also use this condition (slate saddle), keep the aluminum threshold, or remove any threshold/saddle entirely.