

BULLETIN # 13

DATE: May 23, 2024

TO: Laura Li Industries, LLC
Attn: Vincent Sessano

FROM: Brian Dunn, AIA
KG+D Architects, PC

PROJECT: Harrison Recreation & Community Center – PHASE 1
Harrison, NY

RE: Replace Damaged Clay Pipe



Message:

As brought to the attention of the Owner and the Architect by the Contractor on May 8, 2024, it was discovered during excavations that the existing clay sewer pipe running parallel to Calvert Street was damaged in sections. Please provide pricing to replace a section of existing 12” clay pipe with 12” HDPE pipe. The section of replaced pipe will extend the length of the modular block wall and terminate near the south west corner of the building, past the end of the modular block retaining wall, at a location suitable to make the connection. Include the locations of the new pipe on the as-built survey.

Cc: Town of Harrison Engineering Department
File

KG+D Architects, PC

285 Main Street, Mount Kisco, New York 10549
914.666.5900 kgdarchitects.com