

BID ADDENDUM NO. 2

7/22/2024

Pocantico Hills Central School District
Pocantico Hills CSD – Capital Improvements Project 2
3288.008

Central School SED #: 66-08-02-04-0-001-040
Pavilion SED #: 66-08-02-04-7-007-001

The following Addendum items shall be considered a part of the contract documents prepared by HUNT ENGINEERS, ARCHITECTS, LAND SURVEYORS & LANDSCAPE ARCHITECT, DPC.
Bid Document date of June 24, 2024.

Clarifications issued by this Addendum:

N/A

Project Manual Sections issued by this Addendum:

N/A

Drawings issued by this Addendum:

Revisions to Project Manual issued by this Addendum:

ITEM AD2-1 Refer to Section 12 36 00 - Countertops

AMEND subparagraph 2.1, A, 1 to read: "1. Flat Sheet Thickness: $\frac{3}{4}$ " min. Color/pattern, as selected by Architect from manufacturer's full range. Provide solid surface countertops at all new scheduled base (B) cabinets, unless noted otherwise. Provide solid surface sills as indicated on drawings."

ITEM AD2-2 Refer to Section 12 36 00 - Countertops

DELETE the following from subparagraph 2.1, A, 6; "...use marine edge at sinks."

Revisions to Drawings issued by this Addendum:

ITEM AD2-3 Refer to Drawing A5.1 – Enlarged Toilet Plans & Interior Elevations

AMEND Casework Schedule to read: "Cabinet B-27, to be 32 $\frac{1}{2}$ "H, 48" W, 22 $\frac{1}{2}$ " D, Model-3724F, Comments- Art Room B216 Paper Storage"

ADD cabinet to Casework Schedule to read: "B-27A, 35" H, 48"W, 36" D, Model – 2000 Custom Depth, Comments- with Casters".

DELETE base cabinets "B-28" and "B-29" from the schedule in their entirety.

DELETE tall cabinet "T-5" from the schedule in its entirety.

AMEND door style comment on T-7 to read "solid wood doors".

ITEM AD2-4 Refer to Drawing A5.2 – Interior Elevations

AMEND base cabinets on elevation 13/A5.2 & 15/A5.2 that read "B-27" to read "B-27A".

ITEM AD2-5 Refer to Drawing A5.2 – Interior Elevations

ADD textnote to elevation 20/A5.2 that reads: “Provide markerboard surfaced doors on all tall cabinets in room D202.”

ITEM AD2-6 Refer to Drawing E2.4 – Second Floor Lighting & FA Plan- Area C

ADD four (4) exterior type W lights at new exterior wall at rooms C222, C223, C225, & C226.

End of Addendum #2