


- IT IS A REQUIREMENT OF THIS PROJECT THAT ALL WINDOW, DOOR, LOUVER AND ALL OTHER OPENINGS, PENETRATIONS INCLUDING GUT FLUTES IN THE BUILDING EXTERIOR SHALL HAVE THE SURROUNDING GAPS FOR SHIMS & LEVELING FILLED WITH BATT INSULATION STRIPS TO FORM A COMPLETE AIR INFILTRATION BARRIER. IN MANY CASES SMALL BITS & PIECES OF INSULATION WILL REQUIRE BEING FITTED INTO THESE GAPS AT HEAD, JAMBS & SILL S.
- PRIOR TO CLOSURE OF SURROUNDING CONSTRUCTION THE G.C. SHALL PROVIDE THE ARCHITECT WITH ADEQUATE NOTICE FOR REVIEW OF ALL SUCH CONDITIONS.
- NON-EXPANDING SPRAY FOAM FILLER MAY BE PERMISSIBLE FOR SEALING THE BUILDING PERIMETER, IF APPROVED BY THE ARCHITECT.
- ACP (ALUMINUM COMPOSITE PANEL) SYSTEM SHALL INCLUDE MFR APPROVED ALUM. EXTRUDED ATTACHMENT SYSTEM, INCLUDING FIRE TREATED BLOCKING OR OTHER APPROVED SUBSTRATE SHALL BE PROVIDED WHERE NEEDED (EVEN IF NOT SHOWN, AS PART OF THE SYSTEM).
- ACP - PER SPEC W/MFR APPROVED ALUM. EXTRUSION ATTACHMENTS (TYP - SEE NOTE 2A)
- ZINC "REVEAL PANEL" SYSTEM SHALL INCLUDE THE ATTACHMENTS (TO BACKUP WALL, COMPOSED OF GALV. METAL DECK & WELDED PLATE PER DETAILS. PROVIDE MFR APPROVED ST. STEEL ATTACHMENT SYSTEM OF ZOLIPS, FASTENERS & THE LIKE).
- ZINC CLADDING SYSTEMS SHALL INCLUDE WINDOW - HEAD, JAMB, TRIM, CLOSURE & SILL FLASHINGS w/DRIP PER MFR. SEE SPECS FOR FINISH & OTHER REQUIREMENTS.
- PRIOR TO INSTALLATION OF ANY ZINC CLADDING SYSTEM THE MASONRY, STONE OR CAST STONE ADJACENT OR NEAR MUST BE FULLY WASHED DOWN.
- HOLLOW STRUCTURAL STEEL MEMBERS & NESTED STEEL STUDS (CFMF) CONTAINED WITHIN THE EXTERIOR BACKUP WALL SHALL BE INTERNALLY INSULATED (PRIOR TO ERECTION) TO MAINTAIN CONTINUITY OF THE BUILDING ENVELOPE INSULATION.
- PROVIDE BULLNOSE FOR ALL CMU WALLS WITH EXPOSED OUTSIDE CORNERS. REFER TO DETAIL 3C / A903 (EVEN IF NOT SHOWN IN DETAILS).



NOTE: ALL LOCAL DESIGN REQUIREMENTS AND AS NOTED OR REPRESENTED BY THIS DRAWING ARE OWNED BY AND ARE THE PROPERTY OF KG+D ARCHITECTS, PC. ANY REVISIONS, ADDITIONS OR DELETIONS TO THIS DRAWING SHALL BE THE PROPERTY OF KG+D ARCHITECTS, PC. ANY REVISIONS, ADDITIONS OR DELETIONS TO THIS DRAWING SHALL BE THE PROPERTY OF KG+D ARCHITECTS, PC. ANY REVISIONS, ADDITIONS OR DELETIONS TO THIS DRAWING SHALL BE THE PROPERTY OF KG+D ARCHITECTS, PC.

Professional Seal

No.	Date	Issue
5	11/01/2021	ISSUE FOR BID

**ENLARGED SECTIONS and DETAILS**

Job No.	2019-1026	Date	11/01/2021
Scale	AS NOTED	Drawn / Checked	- / -
Sheet Number	A807		

