

BULLETIN #004

DATE: 06/14/2022

TO: All Prime Contractors

ATTN: Piazza, Lombardo, J+M, Talt

FROM: Matt King
KG+D Architects

PROJECT: St. Denis Community School

RE: Subgrade Stabilization Fabric



Upon inspection of the subgrade soil conditions, the special inspector is recommending that a stabilization fabric be placed over the subgrade prior to the importation of the RCA.

The recommended fabric is Tencate Mirafi HP 270 or equivalent. Reference attached e-mail.

cc: Yonkers Public School District - John Carr
Savin Engineers - Nancy Barbera
File

Matt King

From: Burke, Christopher <CBurke2@tectonicengineering.com>
Sent: Tuesday, June 14, 2022 9:45 AM
To: Russell A. Davidson; Eugene Schwarzrock; Cohen, Scott; Morey, Frank A.; Duesel, James J.; Orcutt, James P.; Stier, Mark A.
Cc: Brian Mangan; Matt King; Trevor Hill
Subject: RE: Yonkers School 35
Attachments: Bulletin 003 05.05.22 Alternate Compaction Method.pdf

Russell,

Tectonic takes no exception to this alternate compaction method and we will make sure our inspectors understand it prior to arriving on-site. Based on our field observations this morning, we would also recommend a separation/stabilization fabric (Tencate Mirafi HP270 or equivalent) be placed on top of the approved subgrade, prior to placement of the compacted RCA.

Christopher Burke, Ph.D., P.E., P.M.P.
Vice President, Geotechnical



PRACTICAL SOLUTIONS. EXCEPTIONAL SERVICE.

ENGINEERING - SURVEYING - CONSTRUCTION INSPECTION

1279 Route 300
Newburgh, New York 12550
T 845.567.6656 C 917.575.1792 F 845.567.6248
WWW.TECTONICEENGINEERING.COM cburke2@tectonicengineering.com

[Download my outlook business card](#)

The information transmitted in this e-mail is intended solely for the person or entity to which it is addressed and may contain confidential and/or privileged material. Any review, retransmission, dissemination or other use of any action in reliance upon, this information by persons or entities other than the intended recipient is prohibited and may be unlawful. If you received this in error, please contact the sender and delete the material from any computer.